



المؤسسة العامة القطرية للكهرباء والماء  
Qatar General Electricity & Water Corporation

## TECHNICAL AFFAIRS

المستوفى الفني

TELEFAX MESSAGE	DATE: 24 JAN 2008	TOTAL PAGES: 1
To: Saudi Cable Company		Fax No.+ 974 436 08 70
For the Attention of: Mr. Syed Iqbal Hussain Project Manager		Our Ref.: TA/DO/TE/FX/07/ 101
Contract: GTC/124/2006/D - Saudi Cable Qatar Power Transmission System Expansion - Phase VII (Cables)		


### PQ Documents for Cable Cleats

With reference to your letter ref. no: PH7-SCC-4D-CON-08-0255, dated 16<sup>th</sup> January, 2008, including submission of the revised PQ Documents for Cable Cleats, please be advised as follows:

1. Considering using of subject material in Project Phase VI, GTC/05/2004, M/s S/S Engineer is acceptable as a Vendor of Cable Cleats for 66kV and 132kV Voltage Level for Project GTC/124/2006/D,
2. Technical proposal, type of cable cleats proposed to be used on this Project and all necessary details shall be provided by technical submittal for approval.

This is for your information.

Regards,

  
Abdulla Al Subaie  
Director, Technical Affairs

cc: TE  
cc: Tarek M. El Arabi  
cc: EFC (Fax: 4478 572)

TE  
TEP  
Tarek M. El Arabi

EFC ref.no.:PH7-EFC-4D-CON-07-0077

RECEIVED  
24 JAN 2008  
BY: 