



पावर ग्रिड कारपोरेशन ऑफ इंडिया लिमिटेड
(भारत सरकार का उद्यम)
POWER GRID CORPORATION OF INDIA LIMITED
(A Government of India Enterprise)



केन्द्रीय कार्यालय : "सौदामिनी" प्लॉट नं. 2, सेक्टर-29, गुरुगंज-122 001, हरियाणा
फोन : 2571700 - 719, फैक्स : 2571760, 2571761 एम. मोबाइल
Corporate Office : "Saudamini" Plot No. 2, Sector-29, Gurgaon-122 001, Haryana
Tel. : 2571700 - 719, Fax : 2571760, 2571761 Gmail : "NATGRID"

संदर्भ संख्या/Ref. Number

C/ENGG/SS/ER/BOKARO/CBL/34

Date: 29/05/2014

Sl. No.	Drawing / Document Number	Rev No.	Title	CAT
1	CCI/PROJ/PGCIL-Bokaro-220KV-023	-	Single Phase Link Box with SVL (Make SS Engineering, Chennai)	I
2	CCI/PROJ/PGCIL-Bokaro-220KV-024	-	Single Phase Link Box without SVL (Make SS Engineering, Chennai)	I
3	- (4 Sheets)	-	GTP for 220kV Cable Link Boxes with SVL & Without SVL. (Make SS Engineering, Chennai)	I
4	- (1 Sheet)	-	Datasheet of Surge Arrester System, PolyGrade (Raychem make), CPA-05; Rated Voltage 6.25kV, Nominal Discharge current 10kA	IV
5	CPRI Test Report No.: 392E.ATDIP13S0215 dated 29/07/2013T for IP65 Type Test conducted on Link Box for 132kV Cable System of M/s SS Engineering Make, is accepted for the project.			

CATEGORIES:

- I Approved/Released for fabrication/construction.
- II Approved/Released for fabrication/construction subject to incorporation of comments. Proceed with fabrication/construction and modifications as noted. Revised drawings required.
- III To be resubmitted for approval after incorporating the comments.
- IV For information and record.
- V Not approved.

NOTE: The approval of the drawing conveyed vide this letter does not cover the approval of sub vendor for make of the items. The approval in this respect is to be obtained separately from Quality Assurance Department

(A. Joshi)
DGM(Engg-S/S)